



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

April 12, 2010

Demetrius Williams
Kroger Company
4111 Executive Parkway
Westerville, OH 43081

Re: Storm Water Inspection at Kroger #839/Permit #4GC02315*AG

Dear Mr. Williams:

This letter is written regarding the storm water inspection I conducted at Kroger, located at 1177 Polaris Parkway in Delaware County, on March 22, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

- Vegetation is becoming better established with the exception of erosion noted within the dry basins associated with this site. The erosion must be repaired prior to permit termination.
- Self-Inspections must be conducted every seven days or within 24 hours of a rain event greater than 0.5 inches. Logs of the inspections must be on site available for review.

Post Construction Requirements:


- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://epa.ohio.gov/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.
- Please note the dry basins as noted during the inspection do NOT appear to meet the minimum requirements of the permit.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Demetrius Williams
Kroger Company
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Kroger 839 Lewis Center 03-22-2010