



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

March 30, 2010

Ron Strussion  
Reynoldsburg City Schools  
7244 East Main Street  
Reynoldsburg, OH 43068

**Re: New Summit Road High School and Elementary School  
Permit 4GC03083\* AG, March 18, 2010**

Dear Mr. Strussion:

This letter is written in follow-up to a storm water construction I conducted at Summit Road High School located in Reynoldsburg, Ohio on March 18, 2010. The purpose of the inspection was to evaluate compliance with your General Storm Water Permit. During the inspection the following items were evaluated:

**Sediment and Erosion Controls:**

- It appears less than 20% of the site was protected from erosion with a straw mulch cover, specifically the south central position of the site. Significant areas, specifically east of the stream were not protected as earlier requested.
- I am formally requesting additional information regarding the final discharge point to waters of the state associated with the southwestern impoundment. The Storm Water Pollution Prevention Plan (SWPPP) was unclear regarding the point of discharge to waters of the state. This was requested concurrent with my last inspection report.
- Please demonstrate the temporary stabilization requirements of the General Permit have not been violated with the submittal of your inspection reports.
- The large regional sediment basin located on the southwest corner of the site must be stabilized. This issue was brought to your attention during October of 2009. Corrective actions are expected within seven days from receipt of this letter.
- During the inspection, I noted the installation of the bio retention island in the parking lots. Please continue to keep paved parking lot clear of sediment not jeopardize the intended function. Sediment during the construction phase will directly affect infiltration.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Ron Strussion  
Reynoldsburg City Schools  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c. Kevin Ballog, Smoot Construction

HK/nsm Summit Reynoldsburg March 18, 2010