



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

March 30, 2010

Jon Kletrovetz
Dominion Homes
4900 Tuttle Crossing Blvd.
Dublin, Ohio 43016

Re: Sunbury Meadows Storm Water Inspection

Dear Mr. Kletrovetz:

This letter is written regarding the storm water inspection I conducted at Sunbury Meadows, Delaware County, on March 16, 2010. The agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities.

Sediment and Erosion Controls:

- During the inspection I noticed new areas of disturbance. Measures must be taken to ensure positive drainage to centralized sediment basin.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Sunbury Meadows March 16, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



