



4GC0287420100318

2010/03/18

4GC02874

HOLIDAY INN EXPRESS (NON-EXTENDED STAY)



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

March 18, 2010

Kobil and Associates
5900 Sharon Woods Blvd.
Columbus, OH 43229

Re: Construction Storm Water Inspection Permit Number 4GC02874*AG

Dear Sir or Madame:

This letter is written in follow-up to a construction storm water inspection I conducted at Holiday Inn Express, located on Orion Place in Columbus, Ohio on March 2, 2010. The inspection was conducted to evaluate the sediment and erosion controls as required by your General Storm Water Permit Associated with Construction Activities. The following items were noted:

Sediment and Erosion Controls

- The perimeter controls must be maintained. As I stated in earlier inspection reports, the silt fence must be backed with straw bales or demonstrate an approvable alternative.
- The sediment basin must be completed and modified for sediment controls within two weeks from receipt of this letter.
- Diversions/ Ditches must be established to ensure positive drainage to the pond intended for sediment control.
- All barren areas which remain idle in excess of 21 days must be protected from erosion. All areas of final grade must be protected within 7 days.

Post Construction Requirements:

- Please submit to my attention all design criteria to address the post construction requirements of the General Permit. An electronic submittal to harry.kallipolitis@epa.state.oh.us, is preferred.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Kobil and Associates
Page -2-

If you have questions regarding this letter or my inspection, please contact me at 614-728-3844 or at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Holiday Inn Orion 03-02-2010