



4GC0309620100312

2010/03/12

4GC03096

COLUMBUS COMMONS MASS EXCAV & UTILITY DEMO



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

March 12, 2010

Milton Lewis
Capital South Community Urban Redevelopment Group
150 South Front Street, Suite 210
Columbus, OH 43215

Re: Columbus Commons Mass Excavation and Utility Demolition / Franklin County

Dear Mr. Lewis:

This letter is written regarding the storm water inspection I conducted of the construction activities at the Columbus Commons Mass Excavation and Utility Demolition, located at 100 Columbus City Center Drive, in Columbus Ohio, on March 12, 2010. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

Sediment and Erosion Controls:

There was active construction at the site located at the intersection of Rich and High Streets. The site was not stabilized and erosion was leaving the site. Mud was being tracked from the demolition site on to the Rich Street. Please install controls, such as additional gravel, to prevent mud being tracked on to the road.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO
David Loewendick, S.G. Lowendick and Sons

GLS/nsm Columbus Commons Mass Excavation, March 12, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



