



4GC0315020100312

2010/03/12

4GC03150

WESTERMAN NUCLEAR



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

March 12, 2010

Ezekiel Wolfe
Westerman Company
245 North Broad Street
Bremen, OH 43107

Re: Westerman Nuclear Facility / Fairfield County

Dear Mr. Wolfe:

This letter is written regarding the storm water inspection that I conducted on March 3, 2010, at Westerman Nuclear Facility, located at 1395 Webb Summit Road, in Bremen, Ohio. It appears that there was recent construction activity at this site. Based on the site inspection and the General Storm Water Permit, the following items must be addressed under the storm water permit.

Sediment and Erosion Controls:

It appears that construction activity had previously started at this site. Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and mulch), this specifically applies to stock piles and barren areas located on the site.

The site should have silt fence placed around the perimeter of the site. The erosion controls must be maintained and inspected weekly or after a significant rain event. The weekly log of the inspections must be kept on-site.


Winter Rule: Considerations must be made at this time to ensure all barren areas are protected from erosion in preparation for the upcoming winter months. Please note, in the event that earthmoving activities extend beyond the effective growing season, alternative erosion protection will be required to fully stabilize the site for winter. (i.e., erosion control matting or crimp mulching).

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Ezekiel Wolfe
Westerman Company
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,




Gregory L. Sanders
Environmental Specialist
Storm Water Section
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO

GS/nsm Westerman Nuclear Facility, March 3, 2010

Westerman Nuclear Facility
Need to install erosion controls
Rush Creek Watershed
March 3, 2010
Photo by: Greg Sanders



Westerman Nuclear Facility
Rush Creek Watershed
March 3, 2010
Photo by: Greg Sanders

