



4GR0032420100310

2010/03/10

4GR00324

USF HOLLAND INC



State of Ohio Environmental Protection Agency

Central District Office

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

March 10, 2010

Scott Schaffer
USF Holland
c/o YRC Enterprise Services
1077 George Blvd.
Akron, OH 44309-0471

**Re: Preliminary Storm Water Inspection at USF Holland (4GR00324*DG)
Location: Journal Ave. in Columbus, Ohio**

Dear Mr. Schaffer:

This letter is written in follow-up to a preliminary storm water inspection I conducted at USF Holland in Columbus, Ohio on February 25, 2010. This facility is currently covered under the General Storm Water Permit Associated with Industrial Activities. This preliminary inspection entailed the evaluation of materials and or processes exposed to storm water. Based on my preliminary inspection, the following items were noted:

Storm Water Pollution Prevention Plan (SWPPP):

- A SWPPP must be developed specific for this site. The SWPPP must include a site map which clearly delineates all storm water drainage patterns. All storm water outfalls/discharges from the site must be identified on the SWPPP. All Best Management Practices (BMP's), current and future, must be inclusive in the SWPPP and site map. The SWPPP must be reviewed and updated on a yearly basis to reflect any changes at this facility. Guidance documents for preparing a SWPPP can be found at:

<http://www.epa.gov/npdes/pubs/owm0236a.pdf>

http://www.epa.gov/npdes/pubs/industrial_swppp_guide.pdf

Loading/Unloading:

- Please describe your loading/unloading protocols for evaluation. Include all Best Management Practices (BMP's) implemented for this process as I did note an off loading area on the northern end of the building

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Vehicle Washing:

- Please indicate if there is any mobile power washing activities at this site. Include all BMP's

Fueling Island:

- I noted a fueling island on the property. There are specific expectations regarding storm water pollution prevention associated with fueling operations. Please describe your storm water BMP's associated with this process.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office