



\*4GC0250920100225\*

2010/02/25

4GC02509

KROGER STORE N802



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

February 25, 2010

Chuck Holcomb  
The Kroger Company  
4111 Executive Parkway  
Westerville, OH 43081

**Re: Kroger Store N802  
Permit # 4GC02509\*AG**

This letter is written in follow-up to a construction storm water inspection I conducted at Kroger Store located in Sunbury, Ohio on February 17, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Erosion Controls:**

- Please ensure the sediment basin remains functional until vegetation is established sufficient to controls erosion measures by a minimum vegetative cover of seventy percent.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

HK/nsm Kroger, Sunbury 02-17-10

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

