



4GC0287420100217

2010/02/17

4GC02874

HOLIDAY INN EXPRESS (NON-EXTENDED STAY)



FILE COPY

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 17, 2010

Kobil and Associates
5900 Sharon Woods Boulevard
Columbus, OH 43229

Dear Sir or Madame:

**Re: Construction Storm Water Inspection at Holiday Inn Express
Permit Number 4GC02874*AG**

This letter is written in follow up to a construction storm water inspection I conducted at Holiday Inn Express located on Orion Place in Columbus, Ohio on February 3, 2010. The purpose of the inspection was to evaluate your compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- I would strongly suggest that straw bales are implemented as support in conjunction with the perimeter silt fence. Significant portions of the silt fence were installed incorrectly and would benefit greatly with the straw bale support.
- It appeared that a centralized sediment basin was under construction near the north-central portion of the project. Measures must be established to ensure the sediment basin is installed within ten (10) days from receipt of this letter. Earthen berms or cut diversions must be established to ensure positive drainage from the barren areas to the impoundment intended for sediment control.
- All affected areas which remain barren and idle in excess of 21 days must be protected from erosion. Given the current season, a crimped mulch cover is expected for temporary cover.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: [Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Kobil and Associates

Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. Please provide a response to this letter within seven (7) days of receipt.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/ct Holiday In Express02-03-10 4GC02874