



\*4GC0302420100205\*

2010/02/05

4GC03024

THIRTY-ONE COMPANY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

February 5, 2010

Deb Walsh  
Thirty-One Company  
180 Commerce Boulevard  
Johnstown, OH 43031

**Re: Storm Water Inspection at Thirty-One Company  
Permit #: 4GC03024\*AG**

Dear Ms. Walsh:

This letter is written in follow-up to a construction storm water inspection I conducted, at Thirty-One Company located on Commerce Boulevard in Johnstown on February 2, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

- The site construction is completed. I noted extensive areas of seeding and mulch. Please understand the site must be established with vegetation successful to control erosion which is measures by a minimum vegetative density of 70 Percent.
- Additional seeding may be required this spring to ensure the minimum vegetative density is established

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: [Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Deb Walsh  
Thirty-One Company  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,

A handwritten signature in black ink, appearing to read 'HK', written in a cursive style.

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Thirty-One 02-02-10