



4GR0049320100204

2010/02/04

4GR00493

MID-OHIO WOOD PRODUCTS INC



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 4, 2010

Jay Parkinson
Mid Ohio Wood Products
535 Franklin Ave.
Heath, OH 43056

**Re: Preliminary Storm Water Inspection at Mid Ohio Wood Products
Permit Number 4GR00493*DG**

Dear Mr. Parkinson:

This letter is written in follow up to a preliminary storm water inspection I conducted at Mid Ohio Wood Products located in Licking County on February 2, 2010. This facility is currently covered under the General Storm Water Permit Associated with Industrial Activities. This preliminary inspection entailed the evaluation of materials and or processes exposed to storm water. Based on my preliminary inspection, the following items were noted:

Saw Dust Storage:

- I noted an abundance of saw dust storage on site (SEE FIGURE 1). Measures must be considered to ensure all materials are stored under roof, or equivalent, to minimize off site transport in storm water

Booth:

- Please describe the process associated with the booth noted in FIGURE 2. Please identify any potential threats to storm water associated with this operation.

Inside Drains:

- Please be able to address the drains, if any, inside the facility and the associated point of discharge

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Storm Water Pollution Prevention Plan (SWPPP):

- A SWPPP must be developed specific for this site. The SWPPP must include a site map which clearly delineates all storm water drainage patterns. All storm water outfalls/discharges from the site must be indentified on the SWPPP. All Best Management Practices (BMP's), current and future must be inclusive in the SWPPP and site map. The SWPPP must be reviewed and updated on a yearly basis to reflect any changes at this facility. Guidance documents for preparing a SWPPP can be found at:

<http://www.epa.gov/npdes/pubs/owm0236a.pdf>

http://www.epa.gov/npdes/pubs/industrial_swppp_guide.pdf

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO



Figure 1



Figure 2

