



4GC0284120100204

2010/02/04

4GC02841

MT CARMEL HEALTH SYSTEM & FAIRFIELD MED CTR



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 4, 2010

David Dryden
Greenfield Development Company
6150 East Broad Street
Columbus, OH 43213

Re: Mt. Carmel Health System / Fairfield County

Dear Mr. Dryden:

This letter is written regarding the storm water inspection I conducted on February 2, 2010, of the construction activities at the Mt. Carmel Health System located in the northwest corner of the intersection of Diley Road and Eichhorn Road. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

Sediment and Erosion Controls:

No erosion appeared to be leaving the site and the site appeared to be in compliance with the General Storm Water Permit. Barren areas were stabilized and crimped with straw. It appeared that construction is about completed for this site. A Notice of Termination will be required providing that the post construction requirements have been met. Instructions and forms can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.html>.

Post Construction Requirements:

The General Permit mandates specific water quality treatment for storm water following the completion of construction (see attachment). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at greg.sanders@epa.state.oh.us.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

David Dryden
Greenfield Development Company
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

A handwritten signature in black ink, appearing to read 'G.L.S.', written in a cursive style.

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GLS/nsm Mt. Carmel Health System, February 2, 2010