



4GC0244320100202

2010/02/02

4GC02443

HICKORY CHASE



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Garzarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 2, 2010

Garrett Power
Hickory Chase Community Development Authority
4472 Leap Road
Hilliard OH 43026

**Re: Construction Storm Water Inspection at Hickory Chase
Permit Number: 4GC01758**

Dear Mr. Power:

This letter is written in follow-up to a construction storm water inspection I conducted at Hickory Chase located in Hilliard Ohio on January 6, 2010, the purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- Areas of active construction appear temporarily ceased. Measures are expected to ensure all barren areas are adequately protected from erosion. This specifically applies to the large stockpiles noted on site. In your response letter, please address the construction status of the site and how this will affect compliance with your General Storm Water Permit.
- Due to recent precipitation events, maintenance of controls is expected. Please ensure all controls are inspected and maintained every seven days or within 24 hours of a rain event greater than or equal to 0.5 inches. Logs of all inspections and subsequent corrective actions must be maintained on site available for review.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
[Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Garrett Power
Hickory Chase Community Development Authority
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition please provide a written response to this letter within seven days of receipt.

Sincerely,

A handwritten signature in black ink, appearing to read "Harry Kallipolitis", written in a cursive style.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Hickory Chase 1-6-10