



4GC0312920100202

2010/02/02

4GC03129

ETNA PARKWAY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

February 2, 2010

Jerry Berms
Licking County
20 South Second Street
Newark, OH 43055

Re: Etna Parkway 4GC00548*AG

Dear Mr. Berms:

This letter is written in follow-up to a construction storm water inspection I conducted at Etna Parkway on January 25, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities north of Refugee Road.

Sediment and Erosion Control:

- The intersection of Broad Street and Etna Parkway was protected from erosion with a mulch cover. However due to recent rain events, additional cover is expected
- All sediment basins must be inspected and maintained to ensure compliance with the General Permit. All basins must be cleaned to original design capacity in the event they are more than 50 percent full
- The entire mainline must be protected from erosion with a mulch cover or demonstrate an approvable alternative.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

HK/nsm Etna Parkway, 1-25-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



