



4GC0006420101021

2010/10/21

4GC00064

MISTY MEADOWS SUBDIVISION



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Zazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

October 21, 2010

Floyd E. Wicks
Rockmill Development Corp.
4920 E. Fifth Ave.
Columbus, OH 43219

Re: Misty Meadows / Fairfield County

Dear Mr. Wicks:

This letter is written regarding storm water inspection I conducted of the construction activities at Misty Meadows, located in Fairfield County, on October 19, 2010. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

Sediment and Erosion Controls:

There appeared to be one home under construction during the time of the inspection. The home site had erosion controls in place and no erosion appeared to be leaving the site.

I noted a concrete wash out containment pit on-site that was in need of repair. Please repair the concrete wash out containment pit. Please see attached picture.

There did not appear to be any weekly inspection logs located in the SWP3 mailbox. Please keep copies of the weekly inspections at the site.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,


Gregory L. Sanders
Environmental Specialist
Storm Water Section
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO
James Pate, City of Lancaster
Chris Phelps, Maronda Homes

GS/nsm Misty Meadows, October 19, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Misty Meadows
Repair concrete wash out pit
Hocking River Watershed
October 19, 2010
Photo by: Greg Sanders

