



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

P.O. Box 1049  
Columbus, OH 43216-1049

October 18, 2010

Steve Peck  
Dominion Homes Incorporated  
4900 Tuttle Crossing Boulevard  
Dublin, OH 43016

**Re: Construction Storm Water Inspection at Fox Glen Section 7 Parts A, B, and C and Section 8/  
Fairfield County  
Permit Number: 4GC03321\*AG**

Dear Mr. Peck:

This letter is written regarding a storm water inspection conducted by Stephen Riley of the Ohio EPA at Fox Glen Section 7 Parts A, B, and C and Section 8 located at 1350 feet North of Diley Road and Fox Glen Drive East Pickerington, Oh on October 4, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- During the inspection it was noted that a stream crosses through the construction area with no sediment and erosion controls to protect against turbid storm water discharges. I was assured by the contractor on site, this stream dissipates into a field and does not merge with any other streams. However, sediment controls associated with this area are expected. Perimeter silt fence of sediment trap is expected.
- Please be aware the General Permit states that all sediment controls must be implemented prior to initial grading of the site and that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches to ensure continued effectiveness of the sediment basin.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/hsm Fox Glen Section 7 Parts A,B,&C & Section 8, 10-4-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



