



4GC0212720101014

2010/10/14

4GC02127

LANGFORD MEADOW SECTIONS 6 7 8 SUBDIVISION



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

October 14, 2010

Jay Girard
Darby Homes
985 Schrock Road
Columbus, OH 43229

Re: Langford Meadow, Sec. 6, 7 & 8 / City of Columbus / Franklin County

Dear Mr. Girard:

This letter is written regarding the storm water inspection that I conducted on October 4, 2010, at your development along Brown Road, in Franklin County. The agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities.

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Storm Water Section
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

GS/nsm Langford Meadow, Sec. 6, 7 & 8, October 4, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Kortesi, Director

