



4GCD000220101007

2010/10/07

4GCD0002

CLOVER GROFF RUN STREAM RESTORATION PROJ
AT LATHAM



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

October 7, 2010

Brad Westall
City of Columbus-Division of Parks and Recreation
1111 East Broad Street
Columbus, OH 43205

Re: Notice of Violation

Dear Mr. Westall:

This letter is written in follow-up to a construction storm water inspection I conducted at Clover Groff Run Stream Restoration Phase II located in Scioto and Darby Creek Road Hilliard, Ohio 43026 on September 21, 2010. Based on my site observations and 40CFR122.26 the following items were noted:

- I understand an application has been received requesting coverage under the General Storm Water Permit associated with Construction Activities within the Big Darby watershed. On September 10, 2010, I offered comments to the submitted Storm Water Pollution Prevention Plan. Please be aware the permit coverage for this site has not been granted. This letter serves as a formal Notice of Violation for commencing construction activities prior to authorization under the General Permit associated with Construction within the Big Darby watershed.
- The Storm Water Pollution Prevention Plan was reviewed and comments are provided via E-mail to you dated September 10, 2010.
- Measures are expected to ensure all barren areas are properly protected in preparation for the upcoming winter months. In the event earth disturbing activities extend beyond an effective growing season, alternate erosion protection is expected. This would include but not limited to a crimped straw mulch cover.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to this letter within seven days of receipt.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Clover Groff Stream Restoration 6-24-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

