



4GC0319720101006

2010/10/06

4GC03197

NEPO LLC



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

October 6, 2010

Jim Elter
Elter Building Systems Inc.
PO Box 204
Sunbury, OH 43074

**Re: Notice of Termination Inspection at Nepo LLC / Franklin County
Permit Number 4GC03197*AG**

Dear Mr. Elter:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley of Ohio EPA at Nepo LLC located at 3119 Scioto Darby Executive Court in Hilliard, Ohio on September 14, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. It appeared during the inspection that construction activity is completed for this site. A Notice of Termination will be required provided the following requirements are met:

Sediment and Erosion Control:

- It appears the site lacks proper seeding and does not possess the required 70% vegetative density. Please seed the site within seven (7) days upon receipt of this letter.
- Vegetation must be established sufficient to control erosion which is measured by a minimum vegetative density of 70%.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Jim Elter
Elter Building Systems Inc.
Page -2-

- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at:
<http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO