



\*4GC0313620101006\*

2010/10/06

4GC03136

RESERVOIR POLLUTION REDUCTION PROJECT CIP  
690506



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

October 6, 2010

Mr. Domenick  
City of Columbus, Department of Public Utilities  
910 Dublin Road  
Columbus, OH 43215

**Re: Construction Storm Water Inspection at Reservoir Pollution Reduction  
Project, CIP No. 690506 / Franklin County  
Permit No. 4GC03136\*AG**

Dear Mr. Domenick:

This letter is written regarding a storm water inspection conducted by Stephen Riley of Ohio EPA at **Reservoir Pollution Reduction Project CIP 690506** located at Hoover Reservoir, Sunbury Road, Redbank Road and Central on September 15, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- The silt fence implemented on this site requires maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Please be aware the installed straw wattles are not adequate for sediment control. The control is currently failing and not installed properly. Alternate measures are expected.

**Post Construction Requirements:**


- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Mr. Domenick  
City of Columbus, Department of Public Utilities  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Reservoir Pollution Reduction Project CIP 690506 9-15-2010