



4GCD000520100928

2010/09/28

4GCD0005

CYPRESS WESLEYAN CHURCH



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 28, 2010

Barry Hines
Cypress Wesleyan Church
PO Box 360
Galloway, OH 43119

**Re: Construction Storm Water Inspection at Cypress Wesleyan Church
Franklin County
Permit Number 4GCD00051*AG**

Dear Mr. Hines:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley of Ohio EPA at Cypress Wesleyan Church on September 14, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It appears as though all barren areas on the site have been idle in excess of 21 days. Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Cypress Wesleyan church, 9-14-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

