



4GCD000620100920

2010/09/20

4GCD0006

FRA-62-1.34 PID 79542



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 20, 2010

Jeff Holbrook
ODOT District 6
400 East William Street
Delaware, OH 43065

**Re: Storm Water Inspection at FRA-62-1.34 PID 79542 / Pickaway County
Permit No: 4GCD00063*AG
Notice of Violation**

Dear Mr. Holbrook:

This letter is written in follow up to a construction storm water inspection I conducted jointly with Nikki Bentley of ODOT at FRA-62-1.34 PID 79542 located at US 62 and I-71 Columbus, Ohio on August 19, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. The letter serves as a formal notice of violation for failing to meet the conditions of your General Storm Water Permit. The following were noted:

Sediment and Erosion Control:

- Operator and/or contractor has failed to implement the approved alternative sediment and erosion control plan. The plan mandated temporary and/or permanent erosion protection measures for all barren areas exposed for more than 14 days.
- According to Ms. Bentley, the steep slopes on the south end of the project were never addressed with a temporary and/or permanent cover for barren areas exposed since early May of 2010.
- Failure to implement the alternative sediment and erosion control plan represents a direct violation of the general storm water permit.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Jeff Holbrook
ODOT District 6
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at: harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm US 62 ODOT 8-30-2010