



\*4GC0335820100920\*

2010/09/20

4GC03358

WALNUT C & DD



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

September 20, 2010

Jerry Mock  
2480 Leonard Road  
Baltimore, OH 43105

**Re: Construction Storm Water Inspection at Walnut C & D Facility / Fairfield County  
Permit Numbers: 4GC02852\*AG, 4GC03358\*AG**

Dear Mr. Mock:

This letter is written regarding a storm water inspection I conducted at Walnut C & D Facility located at 8675 Lancaster-Newark Road in Baltimore, Ohio on August 31, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

**Sediment and Erosion Control:**

- During my inspection, I noted the excavation of C&D landfill pit, no positive offsite drainage noted. Sediment controls are expected once offsite drainage is established.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at: [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us). In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Walnut C&D, Facility 8-31-2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korieski, Director

