



4GC0308320100920

2010/09/20

4GC03083

NEW SUMMIT RD HIGH AND ELEMENTARY SCHOOL



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 20, 2010

Ron Strussion
Reynoldsburg City School District
7244 East Main Street
Reynoldsburg, OH 43068

**Re: Construction Storm Water Inspection at Summit High School Complex /
Licking County
Permit Number 4GC03083*AG**

Dear Mr. Strussion:

This letter is written in follow-up to a construction storm water inspection I conducted at 8579 & 8591 Summit Road Reynoldsburg, Ohio 43068 on August 18, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It appears as the majority of the site has been seeded and mulched.
- Please maintain retention pond skimmers until seeding is established for the entire site.

Post Construction:

- Following a recent rain event, it appears as though the three western most bio basins are clogged and not infiltrating as intended. Corrective measures are expected within 21 days of receipt of this letter.
- Corrective measures are expected to ensure a micropool and forebay are installed for both regional impoundments.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Summit High School 6-28-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





24

