



4GC0324920100920

2010/09/20

4GC03249

ROSE RUN STREAM RESTORATION



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 20, 2010

Bill Dorman
City of New Albany
7800 Bevelhymmer Road
PO Box 188
New Albany, OH 43054

**Re: Construction Storm Water Inspection at Rose Run Stream Restoration
Franklin County
Permit Numbers: 4GC03249*AG**

Dear Mr. Dorman:

This letter is written regarding a storm water inspection I conducted at Rose Run Stream Restoration located at the south west corner of the intersection of Market Street and Dublin Granville Road in New Albany, Ohio on September 8, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Controls:

- I noted the efforts associated with treating the water associated with dewatering activities. The end result was not acceptable. I made recommendations to place dewatering bags farther into the woods to provide additional treatment.
- Please ensure future dewatering activities do not result in turbid discharges to waters of the state.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at: harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Rose run Stream Restoration 9-8-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

