



4GC0114720100916

2010/09/16

4GC01147

PATASKALA TOWN CENTER



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 17, 2010

Al Coughlin
Coughlin Automotive
71 East Wilson Bridge Road
Worthington, OH 43085

**Re: Construction Storm Water Inspection at Pataskala Town Center / Licking County
Permit Number: 4GC01147 *AG**

Dear Mr. Coughlin:

This letter is written regarding a storm water inspection I conducted at Coughlin Automotive located on State Route 16 in Licking County on August 27, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Post Construction

- The pond has not been modified to address post construction requirements. The current riser appears to jeopardize the integrity and intended function of the regional basin. Corrective measures are expected within 14 days of receipt of this letter.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Al Coughlin
Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Coughlin Automotive 8-27-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

