



4GC0332220100916

2010/09/16

4GC03322

INDIAN MOUND PARK



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 17, 2010

Justin Loesch
City of Columbus Recreation and Parks Department
1111 East Broad Street, Suite 101
Columbus, OH 43205

**Re: Construction Storm Water Inspection at Indian Mound Park / Franklin County
Permit No: 4GC03322*AG**

Dear Mr. Loesch:

This letter is written regarding a storm water inspection conducted by Stephen Riley of Ohio EPA at Indian Mound Park located at 3901 Parsons Avenue, Columbus, Ohio on September 7, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Please be aware the installed straw wattles are not adequate for sediment control. The control is currently failing and not installed properly. Alternate measures, such as silt fencing, are expected, or demonstrate an appropriate alternative.
- Please install control measures over the existing storm drains.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Justin Loesch
City of Columbus Recreation and Parks Department
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Indian Mound Park 9-7-2010