



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 16, 2010

Carrie Morrow
Columbus & Franklin County Metro Parks
1069 West Main Street
Westerville, OH 43081

**Re: Pre-Construction Storm Water Inspection at Camp Chase Trail
Madison County
Permit Number: 4GCD00069*AG**

Dear Ms. Morrow:

This letter is written regarding a storm water inspection conducted by Stephen Riley of the Ohio EPA at Camp Chase Trail located between West Jefferson-Kiousville Road and River Street on September 2, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Maintenance:

- The silt fence along the trail leading back to the borrow pile requires maintenance or reinstallation to ensure a proper functioning condition. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Camp Chase Trail 9-2-2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director



