



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 16, 2010

Stephen Hume
City of London
6 East Second Street
London, OH 43140

**Re: Construction Storm Water Inspection at Keny Road Extension Project
Madison County
Permit Number 4GC03299 *AG**

Dear Mr. Hume:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley of the Ohio EPA from the existing Keny Road to State Route 38 on September 2, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- At the last intersection before the Keny Road extension meets 38, there is a sloped barren area sloping towards the road (Figure 1). Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Stephen Hume
City of London
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

cc: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm City of London Keny road Extension Project 9-2-2010




Figure 1: Barren area in need of erosion control

