



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 16, 2010

Daryl Wolfe
Circleville First Church of Christ In Christian Union
436 E Ohio Street
Circleville, OH 43113

**Re: Construction Storm Water Inspection at Circleville First Moving Forward US 22
Pickaway County
Permit Number 4GC03240*AG**

Dear Mr. Wolfe:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley of Ohio EPA at Circleville First Moving Forward US 22 in Stoutsville, Ohio on September 7, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- There is a lack of controls leading into the stream on the south side of the site. While onsite, I was assured by the contractor that controls would be implemented that day.
- Please be aware the General Permit states that a sediment pond is required for all disturbed areas within a common drainage area exceeding ten (10) acres. Based on the preliminary site assessment, it appears that a centralized sediment basin will be required for this site. Please indicate in your response letter if the ten (10) acre condition of the permit has been exceeded and consequently include the construction schedule addressing the installation of a sediment pond for this site. All sediment impoundments must be sized with a sediment storage volume of sixty-seven (67) cubic yards per acre of drainage for the dewatering zone and thirty seven (37) cubic yards per acre of disturbance for the sediment settling zone. Please refer to the following link for assistance:
<http://www.dnr.state.oh.us/water/rainwater/default/tabid/9186/default.aspx>

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Ohio EPADivision of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO