



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 15, 2010

Mary Jan Santos
Delaware County District Library
84 East Winter Street
Delaware, OH 43015

**Re: Construction Storm Water Inspection at Delaware Co District Library-Orange Twp
Branch / Delaware County
Permit Number: 4GCO00013*AG**

Dear Ms. Santos:

This letter is written regarding a storm water inspection conducted by Abigail Tamkin and Megan Reising of the Ohio EPA at the Delaware County District Library-Orange Twp. Branch located at Gooding Boulevard—Lot 7529 on August 31, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The silt fence on the northern side of the project has become overrun by the adjacent stockpile. Please ensure this silt fence is repaired.
- The sediment basin appears to have been impacted with sediment, exceeding 50% of its design capacity and will need cleaned out to ensure the proper sediment storage volume.
- The storm sewer outlet on the eastern side of the project, as well as the outlet on the pond on the west side of the project, does not appear to have proper sediment controls in place. Please install a temporary riser or skimmer to minimize off-site sediment transport.
- Concrete washout activities were observed outside of the designated concrete washout pit. These activities were observed near a storm sewer basin outlet, endangering waters of the state. Please direct all concrete washout to designated containment areas to minimize impact to public waters.

It is my understanding that these concerns were conveyed to Kenneth O. Elliot of Elford, Inc., who was on-site at the time. It is my understanding that the silt fence and the clean out of the sediment basin were already being planned for at the time of the inspection.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Mary Jan Santos
Delaware Co District Library
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Delaware Co District Library-Orange TWP Branch 8-31-2010