



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

September 15, 2010

Scott Overturf
Orange Township Board of Trustees
1680 East Orange Road
Lewis Center, OH 43035

**Re: Construction Storm Water Inspection at Glen Oak Park
Delaware County
Permit Number: 4GC03330*AG**

Dear Mr. Overturf:

This letter is written in follow-up to a construction storm water inspection conducted by Megan Reising and Abigail Tamkin at Glen Oak Park located at 7126 Blue Holly Drive in Delaware County, Ohio on August 31, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The catch basin at this site will require attention to address sediment control (see figure 1). Please install appropriate inlet protection or demonstrate an approvable alternative.
- Please be aware the General Permit states that a sediment pond is required for all disturbed areas within a common drainage area exceeding ten (10) acres. Based on the preliminary site assessment, it appears that a centralized sediment basin will be required for this site.

Maintenance:

- The current log at this site had last preformed an inspection on June 30, -2010. This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Scott Overturf
Orange Township Board of Trustees
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Glen Oak Park 8-31-2010

Glen Oak Park
Alum Creek Watershed

Photo by Megan Reising and Abigail Tamkin
8-31-2019



Figure 1. The catch basin requires protection from sediment

