



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

September 15, 2010

John Roslovic
Roslovic Building Company
600 Morrison Road
Gahanna, OH 43230

**Re: Construction Storm Water Inspection at Havens Corner Office Park
Franklin County
Permit Number: 4GC02959*AG**

Dear Mr. Roslovic:

This letter is written regarding a storm water inspection I conducted at Havens Corner Office Park located at the corner of Havens Corner Road and Waggoner Road on August 19, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The southern sediment basin has been installed.
- The silt fence directly in front of the outlet structure of this basin fails to meet the intent of appropriate sediment controls (see figure 1). A temporary riser/skimmer must be installed within 7 days from receipt of this letter.
- Entire site must be seeded prior to the onset of the winter months.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Roslovic Building Company
John Roslovic
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Havens Corner Office Park 8-30-2010




Figure 1: Structure fails to meet intent of appropriate sediment controls

