



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

December 1, 2009

Ron Strussion
Reynoldsburg City Schools
7244 East Main Street
Reynoldsburg, OH 43068

**Re: New Summit Road High School and Elementary School
Permit #4GC03083*AG, November 13, 2009**

Dear Mr. Strussion:

This letter is written in follow-up to a storm water construction I conducted at Summit Road High School located in Reynoldsburg, Ohio on November 13, 2009. On this date I met with your contractor Kevin Ballog of Smoot Construction. During the inspection, the following items were evaluated:

Sediment and Erosion Controls:

- In the event earth disturbing activities extend beyond an effective growing season, alternate erosion controls such as crimp mulching will be expected in preparation for the upcoming winter months. This applies to the entire site.
- Install a diversion, running north to south to ensure positive flow of storm water to the eastern sediment basin which incorporates a skimmer.
- Connect, via a perimeter diversion, the 4 sediment traps located on the eastern portion of the stream. Continue draining the sediment traps following each precipitation event allowing a minimum of 48 hours settling time.
- Install a diversion, running south to north to ensure positive flow of storm water to the eastern sediment basin which incorporates a skimmer.
- Install a diversion, running north to south to ensure positive flow of storm water to the sediment trap on the extreme southeastern portion of the site, west of the stream.
- Clean and stabilize the sediment pond located on the extreme southwestern portion of the site.
- I remain concern regarding the final point of discharge to waters of the state associated with the southwestern impoundment. The Storm Water Pollution Prevention Plan must be updated to reflect discharges to waters of the state.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director




Ron Strussion
Reynoldsburg City Schools
Page -2-

Permitting Requirements:

Please provide the appropriate permits for the 4 stream crossings within a linear mile associated with this site. It appears the limitations for the nationwide permit have been exceeded.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO
Kevin Ballog, Smoot Construction