



4GR0006520091109

2009/11/09

4GR00065

ALLEN MILK CO - DIV OF T MARZETTI CO



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 9, 2009

J. Wallace
Allen Milk Company
Division of Marzetti Co.
1709 Frank Road
Columbus, OH 43216

Re: Preliminary Storm Water Inspection at Allen Milk Company (4GR00065*DG)

Dear J. Wallace:

This letter is written in follow-up to a preliminary storm water inspection I conducted at Allen Milk Company in Columbus, Ohio on November 3, 2009. This facility is currently covered under the General Storm Water Permit Associated with Industrial Activities. This preliminary inspection entailed the evaluation of materials and or processes exposed to storm water. Based on my preliminary inspection, the following items were noted:

Tank Farm:

- Large tanks were noted protruding from the building which should incorporate secondary containment

Loading/Unloading:

- Please describe your loading/unloading protocols for evaluation. Include all Best Management Practices (BMP's) implemented for this process.

Vehicle Washing:

- Please indicate if there is any mobile power washing activities at this site. Include all BMP's.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



J. Wallace
Allen Milk Company
Division of Marzetti Co.
Page -2-

Storm Water Pollution Prevention Plan (SWPPP)

- A SWPPP must be developed specific for this site. The SWPPP must include a site map which clearly delineates all storm water drainage patterns. All storm water outfalls/discharges from the site must be indentified on the SWPPP. All Best Management Practices (BMP's), current and future must be inclusive in the SWPPP and site map. The SWPPP must be reviewed and updated on a yearly basis to reflect any changes at this facility. **Please submit the SWPPP to my attention (emailed preferred) for review.** Guidance documents for preparing a SWPPP can be found at:

<http://www.epa.gov/npdes/pubs/owm0236a.pdf>

http://www.epa.gov/npdes/pubs/industrial_swppp_guide.pdf

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO