



4GC0224820091105

2009/11/05

4GC02248

THE SHOPPES AT EAST BROAD



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 5, 2009

Tim Muckley
Glitz and Associates Inc.
4835 Munson Street NW
Canton, OH 44718

Re: Storm Water Inspection at the Shoppes at East Broad/Permit #4GC02248*AG

Dear Mr. Muckley:

This letter is written in follow-up to a construction storm water inspection I conducted at The Shoppes at East Broad located at Broad Street and East Waggoner Road in Franklin County on July 20, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Stream Restoration Efforts:

- The stream restoration on the northern portion of the facility has been completed. The restoration efforts addressed the past compliance issues for the site. The stream restoration will be evaluated prior to permit termination to ensure a successful vegetative stand and a stable condition. (see photo)

Sediment and Erosion Controls:

- Erosion to the centralized pond entrance was noted which will require repair (see photo)
- The barren areas have been seeded with vegetation established.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at: harry.kallipolitis@epa.state.oh.us.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Shoppes at East Broad 10-22-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





Figure 1: Stream Restoration Efforts



Figure 2: Erosion to entrance of centralized basin

