



4GC0285720091105

2009/11/05

4GC02857

UPPER ARLINGTON FIRE STATION #72



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 5, 2009

Jerry Moore
Upper Arlington Fire Department
3600 Tremont Road
Upper Arlington, Ohio 43221

**Re: Construction Storm Water Inspection at Upper Arlington Fire Station #72
Permit Number 4GC02857*AG**

Dear Mr. Moore:

This letter is written in follow-up to a construction storm water inspection I conducted at Upper Arlington Fire Department #72 located on Reed Road on October 22, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- The perimeter controls appear to be well maintained. Please ensure continued maintenance to ensure a proper functioning condition.
- Self-Inspection reports must be maintained on site and conducted every seven days or within 24 hour of a precipitation event equal to or greater than 0.5 inches
- Please ensure all barren areas are protected from erosion in preparation for the upcoming winter months.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
[Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Jerry Moore
Upper Arlington Fire Department
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohn, Water Quality Supervisor. DSW/CDO

HK/nsm Upper Arlington Fire Department #721 10-22-09