



\*4GC0285820091105\*

2009/11/05

4GC02858

WELLINGTON SCHOOL



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

November 5, 2009

Laura Cooke  
The Wellington School  
3650 Reed Road  
Upper Arlington, Ohio 43220

**Re: Construction Storm Water Inspection at Wellington School,  
Permit 4GC02858\*AG**

Dear Ms. Cooke:

This letter is written in follow up to a construction storm water inspection I conducted at Wellington School located on Reed Road on October 22, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

**Sediment and Erosion Controls:**

- The perimeter controls appear to be well maintained. Please ensure continued maintenance to ensure a proper functioning condition.
- Self-Inspection reports must be maintained on site and conducted every seven days or within 24 hour of a precipitation event equal to or greater than 0.5 inches
- Please ensure all barren areas are protected from erosion in preparation for the upcoming winter months.

**Post Construction Requirements:**

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:  
[Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



Laura Cooke  
The Wellington School  
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at: [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us).

Sincerely



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Wellington School 10-22-09