



4GC0027120091105

2009/11/05

4GC00271

BRANDY MILL ESTATE SECTION 2



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 5, 2009

Rich Conie
Maronda Homes Inc.
3811 Twin Creeks Drive
Columbus, OH 43206

Dear Mr. Conie:

This letter is written regarding the storm water inspection that I conducted at Brandy Mill Estates located in Licking County, on November 5, 2009. I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed.

Sediment and Erosion Controls:

1. The site remains well established with a vegetative cover sufficient to control erosion. In addition the temporary risers for the outlet structures appear to remain functioning at this time. These risers must remain until all areas are adequately protected from erosion or be able to demonstrate an approved alternative.
2. Please note that the orifice plates must be installed immediately upon removal of the temporary risers to ensure compliance with the post construction requirements of this permit.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Brandy Mill Estates 11-5-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

