



\*4GC0313220091105\*

2009/11/05

4GC03132

IMANIFOLD & PHALOR



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

November 5, 2009

Doug Emert  
Ricap Construction  
2040 Fairwood Avenue  
Columbus, OH 43207

**Re: Manifold & Phalor / Fairfield County**

Dear Mr. Emert:

This letter is written regarding the storm water inspection that I conducted on October 26, 2009, at the Manifold & Phalor site located along Busey Road, west of Diley Road. It appears that there was recent construction activity at this site. Based on the site inspection and the General Storm Water Permit, the following items must be addressed under the storm water permit.

**Sediment and Erosion Controls:**

It appears that construction activity has just started at this site. Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and mulch), this specifically applies to stock piles and barren areas located on the site. Please see attached pictures.

The site should have silt fence placed around the perimeter of the site. The erosion controls must be maintained and inspected weekly or after a significant rain event. The weekly log of the inspections must be kept on-site.

Winter Rule: Considerations must be made at this time to ensure all barren areas are protected from erosion in preparation for the upcoming winter months. Please note, in the event that earthmoving activities extend beyond the effective growing season, alternative erosion protection will be required to fully stabilize the site for winter. (i.e., erosion control matting or crimp mulching).

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

A handwritten signature in black ink, appearing to read 'G L Sanders', written in a cursive style.


Gregory L. Sanders  
Environmental Specialist  
Storm Water Section  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO

GS/nsm Manifold & Phator, October 26, 2009

**Manifold & Phalor**  
**Install erosion controls**  
**Walnut Creek Watershed**  
**October 26, 2009**  
**Photo by: Greg Sanders**



**Manifold & Phalor**  
**Install erosion controls**  
**Walnut Creek Watershed**  
**October 26, 2009**  
**Photo by: Greg Sanders**

