



4GC0312920091026

2009/10/26

4GC03129

ETNA PARKWAY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

October 26, 2009

Jerry Berms
Licking County
20 South Second Street
Newark, OH 43055

Re: Etna Parkway 4GC00548*AG

Dear Mr. Berms:

This letter is written in follow up to a construction storm water inspection I conducted at Etna Parkway located on October 16, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities south of Broad Street

Sediment and Erosion Control:

- During the inspection, I noted the initial phases of earth disturbing activities. Silt fence has been installed down slope of the barren areas. Please understand once the drainage ditches are established, the silt fence will not function as intended as storm water will be routed through the ditches and not the silt fence.
- Once drainage ditches are established, sediment traps/basins will be expected to ensure effective sediment control. The sediment basin implementation will be closely evaluated to ensure compliance with your permit.
- Additional sediment controls are expected with the construction activities near the stream crossings.
- Please understand, in the event earth disturbing activities extend beyond an effective growing season, **alternate erosion controls such as crimp mulch or equivalent is expected** to ensure effective control through the winter months.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Ohio EPA
Division of Surface Water

HK/nsm Etna Pkwy 10-16-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

