4GC0268220091022

2009/10/22	4GC02682	VILLAGE CREEK CENTER

OhioEPA
State of Ohio Environmental Protection Agency

STREET ADDRESS:
Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office
TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:
P.O. Box 1049
Columbus, OH 43216-1049

October 19, 2009

Ray Massa
Creative Land Concepts, LLC
1439 Boswall Drive
Worthington, OH 43085

Re: Village Creek Center / Franklin County

Dear Mr. Massa:

This letter is written regarding a storm water inspection that I conducted at Village Creek Center located west of Alum Creek Drive, north of Lindsay Road and south of Maureen Boulevard in Obetz, Ohio on October 15, 2009. I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Village Creek Center, October 15, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Printed on Recycled Paper

Ohio EPA is an Equal Opportunity Employer