



4GC0245420091020

2009/10/20

4GC02454

IFRA-62-(9.52)(10.02) PID - 20880



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

October 20, 2009

Brad Jones
400 East Williams Street
Delaware, OH 43015

Re: Storm Water Inspection State Route 62 4GC02454*AG

Dear Mr. Jones:

This letter is written in follow-up to a construction storm water inspection I conducted at State Route 62 Improvement Project through Gahanna, Ohio on September 24, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- Currently, the majority of the storm water run-off is contained within the excavation limits of the project. Once positive offsite drainage is established inlet protection or equivalent will be required to ensure effective sediment controls. Inlet protection elevations should be set to compensate for the threat of flooding of State Route 62.
- Please keep in mind erosion protection is required in preparation for the upcoming winter months.

Post Construction Requirements:


- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Brad Jones
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at: harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office