



4GC0303620091008

2009/10/08

4GC03036

WASHINGTON HIGH SCHOOL



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

October 8, 2009

Keith Brown
Washington Court House City Schools
306 Highland Avenue
Washington Court House, OH 43160

Re: Storm Water Inspection at Washington High School/Permit #4GC03036*AG

Dear Mr. Brown:

This letter is written in follow up to a construction storm water inspection by Amber Miller and Rachelle Howe, of the Ohio EPA, at Secure Washington High School located at 1200 Willard Street in Fayette County, on September 11, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- The site appears to be void of sediment controls. In order to meet the requirements of the General Storm Water Permit, silt fence should be installed along Willard Street to prevent sediment from leaving the site (see Photo Figure 1).

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: [Http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx](http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Keith Brown
Washington Court House City Schools
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



For HK

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Washington High School 9-11-09

Washington High School
Paint Creek Watershed
Photo by: Rachelle Howe
September 11, 2009




Figure 1: Willard Street

