



4GC0204520091008

2009/10/08

4GC02045

RIVER RUN SUBDIVISION



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

October 8, 2009

Bruce Miller Jr.
River Run of Powell, LLC
155 Green Meadows Drive South
Lewis Center, OH 43065

Re: Construction Storm Water Inspection at River Run Subdivision

Dear Mr. Miller:

This letter is written in follow-up to a construction storm water inspection I conducted at River Run Subdivision located at State Route 315 and Jewett Road on September 15, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls

- The perimeter silt fence associated with recent lot developments, specifically located at the northeast quadrant of this site has failed and will require maintenance.
- The drainage ditches associated with the roads of this development continue to erode and remain in violation of the General Storm Water Permit. This was brought to you attention via my last inspection report.
- The centralized sediment pond has significant sediment accumulation and will require cleaning.
- Please re-wrap the riser structure with silt fence to ensure effective sediment control.
- There are significant barren and idle areas which will require protection from erosion.
- The temporary access road, located directly off of State Route 315, continues to result in significant erosion of the associated cut slopes. Corrective measures are necessary to stabilize this area or eliminate this road to minimize impact to the Olentangy River. Again this was brought to you attention via my last inspection report.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

Enforcement:

- This site is currently under consideration for formal enforcement activities. Continued violations have been well documented, concurrent with this last construction season. Corrective measures to abate these violations, as stated above, are expected within ten (10) days of receipt of this letter.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,



Harry Kallipolitis
For HK

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO