




**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Hardy, Director



NOTICE OF VIOLATION – ACTION REQUIRED

Re: Hancock County
Green Meadow MHP
Community Water System
PWS ID# OH3200812
STU ID# 3254803

March 9, 2012

Mr. Gary Greiwe, Owner
Greiwe Rentals
1005 Harmon Street
Findlay, Ohio 45840

Dear Mr. Greiwe:

The Public Water System serving Green Meadow MHP is in violation of the Ohio Administrative Code (OAC) for failure to submit the following Monthly Operating Report(s) (MOR) required by OAC 3745-83-01 (I) and/or OAC 3745-81-75.

Language for MI (MOR Inadequate/Missing Content) Violation

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. OAC Rule 3745-83-01(G) (1) & (2) requires the public water system owner to monitor both the free and combined chlorine residuals at least once every day.

A review of February 2012 monthly report showed 7 days during the month, a chlorine residual was not being maintained in the distribution system. Take steps to immediately correct this problem.

If you have any questions please call me at 419-373-3089.

Sincerely,

Jill A. Schiefer
Division of Drinking and Ground Waters

/llr

pc: DDAGW – NWDO

