



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

P.O. Box 1049  
Columbus, OH 43216-1049

October 8, 2009

Pastor Virgil Phillips  
House of Blessings Worship Center  
3633 Big Run South Road  
Grove City, OH 43123

**Re: House of Blessings Worship Center / Franklin County**

Dear Pastor Phillips:

This letter is written in follow up to a construction storm water inspection that I conducted at the House of Blessings Worship Center located at 3633 Big Run South Road on September 30, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following was noted:

**Sediment and Erosion Controls:**

- It appears the sediment and erosion controls observed during the inspection are well maintained and functioning as intended. Please continue to inspect and maintain these sediment and erosion controls every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches, as outlined by the General Permit, to ensure continued effectiveness of the sediment controls.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm House of Blessings Worship Center, September 30, 2009

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

