



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

October 7, 2009

Jim Elliott
Preferred Living
470 Olde Worthington Road #470
Westerville, OH 43082

Re: Storm Water Inspection at Kenyon Square II/Permit #4GC02948*AG

Dear Mr. Elliott:

This letter is written in follow-up to a construction storm water inspection by Amber Miller and Rachelle Howe, of the Ohio EPA, at Kenyon Square II located at 9262 Worthington Road in Delaware County on September 17, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- The sediment fence along Worthington Road requires repair (See Photo Figure 1).
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Kenyon Square II 9-17-09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

12






Figure 1

100-100000

