



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

October 7, 2009

Gayle Fosnaugh
City of Circleville
114 West Franklin Street
Circleville, OH 43113

**Re: Storm Water Inspection at Mary Virginia Crites-Hannan Park
Pickaway County, Permit #: 4GC02757*AG**

Dear Ms. Fosnaugh:

This letter is written in follow-up to a construction storm water inspection by Clarissa Lawlis, of the Ohio EPA, at Mary Virginia Crites-Hannan Park located at the northeast corner of the intersection of State Route 188 and Pontious Road in Circleville, Ohio on September 15, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Barren Areas: 21 Day Rule:

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Controls:

- The perimeter controls for this site appear to be functioning as intended. Please be aware the general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches to ensure continued effectiveness of the sediment basin.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Gayle Fosnaugh
City of Circleville
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Handwritten signature of Jeffrey P. Bohne, with "for HK" written below it.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO