



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

October 6, 2010

Laurie Pogel
Henkel Surface Tech
421 London Road
PO Box 363
Delaware, OH 43015

**Re: Industrial Storm Water Inspection at Henkel Surface Tech.
Delaware County
Permit No: 4GR00198*DG**

Dear Ms. Pogel:

This letter is written in follow-up to a preliminary industrial storm water inspection I conducted at Henkel Surface Tech located at 421 London Road Delaware, Ohio on September 13, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Industrial Activities. During the inspection, the following items were noted:

Loading and Unloading Zones:

- During the inspection, I noted the loading and unloading zone areas associated with the area. The Storm Water Pollution Prevention Plan should address the best management practices associated with all loading and unloading associated with the facility. This would include the use of containment self contained loading and unloading pads to minimize the threat to storm water pollution.

External Storage:


- There were several barrels and totes noted outside of the facility. Special considerations must be addressed to implement best management practices in order to minimize storm water pollution associated with this staging area. This would include but not be limited to the use of covered and contained areas to minimize potential releases associated with leaks and/or spills.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Laurie Pogel
Henkel Surface Tech
Page -2-

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at: harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Henkel Surface Tech 9-20-2010